







## ITB17/01555 - Construction of 19 biomass based heating systems in conjunction with solar collectors for domestic hot water (4 Lots)

Supplemental clarifications to email inquiries as of 09/08/2017:

In relation to the clarification questions and answers published on 02 August 2017, bidders should also consider the next supplemental clarifications:

- 1. For Site 1.1 (Busila) the requirement envisages installation of 2 boilers of 150 kW and 100 kW each fueled with agro-briquettes. Updated BOQs including the relevant corrections is published as of 09/08/2017 and bidders hall use the updated version in the preparation of their bids.
- 2. For Site 2.2 (Falestii Noi) the requirement envisages installation of 2 boilers of 150 kW fueled with agro-briquettes. Updated BOQs including the relevant corrections is published as of 09/08/2017 and bidders hall use the updated version in the preparation of their bids.
- 3. For Sites 2.4 (Ciuciulea), 4.2 (Cneazevca), 4.3 (Enichioi) and 4.4 (Obileni) in all these cases the requirement envisages installation of boilers fueled with agro-briquettes. The existing BOQs prevail over the Design Documents in this case.