



Invitation to Bid ItB23/02632 Questions and Answers

Ref. no. ItB23/02632

Date: 04/05/2023

Subject: EU4MD/ Reconstruction and revitalization of Cahul Town Centre

Q1. What are the specifications for concrete slabs for paving?

A1. It is necessary to install a "Brick" (10cm x 20cm x 6cm) vibrating press pavement, gray, white with granite surface, black with granite surface, specific gravity minimum 135 kg/m². The volumes for each type /color/texture of the pavement are indicated in the Lists with quantities of works (BoQ).

Q2. Please specify the characteristics and type of material for finishing the external stairs at the entrance to the Palace of Culture "Nicolae BOTGROS".

A2. It was decided to use the following material for finishing the exterior stairs at the entrance to the Palace of Culture: steel grey granite stone steps, ready milled, 20mm thick and non-slip surface. Mounting technology - according to the design drawing on a support layer, coordinated with the supplier of steps.

Q3. Where can be stored the construction materials needed for the execution of the work, for example: cement, sand, gravel, pavement, curbs, if it will be in large quantities?

A3. The construction company will coordinate it with the technical supervisor and with the City Hall, on site.