

**INVITATION TO BID
Amendment no. 1**

Ref. no. ITB26/03325

Date: **07/09/2026**

Subject: Renovation and Modernization Works at the MFA Premises

Dear Sir/Madam,

1. The Minutes of the Pre-Bid Meeting and Site Visit held on 03 September and 04 September 2026, respectively, are attached to this Amendment and form an integral part of the solicitation documents.
2. UNDP Moldova hereby amends the Invitation to Bid:
 - a) **Annex 1: Bill of Quantities (English) and Annex 2: Bill of Quantities (Romanian)** have been replaced in their entirety with revised versions prepared using Form No. 1 from WinCmeta. The previous files of Annex 1 and Annex 2 are hereby superseded. Bidders shall use the revised, unified Form No. 1 versions of Annex 1 and Annex 2 for the preparation and submission of their financial bids. To establish compliance and verify the unit rates, bidders are required to submit the supporting detailed cost documentation (Resource Sheets) in Forms No. 3, 5 and 7 generated using WinCmeta or equivalent, in accordance with national legislation and the ITB requirements
 - b) **Annex 4 - Technical Compliance Table** has been replaced with a revised version, the following changes have been made to the technical requirements:

Item	Original text (as in ITB)	Amended specifications
SA_MASI: 1. Fire-rated doors EI30		
Type / dimensions	As per final door schedule and drawings: • U-1 – external full fire-rated door EI30, aluminium, opening size 1200 × 2100 mm • U-2 – full fire-rated door EI30, MDF, opening size 1200 × 2100 mm • U-6 – glazed fire-rated door EI30, MDF with fire-rated glass, opening size 1200 × 2200 mm • U-8 – external full fire-rated door EI30, aluminium, opening size 1200 × 1950 mm Color(s) to be confirmed with designer during the implementation stage.	As per final door schedule and drawings: • U-1 – external full fire-rated door EI30, aluminium, opening size 1200 × 2100 mm • U-2 – full fire-rated door EI30, HPL, opening size 1200 × 2100 mm • U-6 – glazed fire-rated door EI30, HPL with fire-rated glass, opening size 1200 × 2200 mm • U-8 – external full fire-rated door EI30, aluminium, opening size 1200 × 1950 mm Color(s) to be confirmed with designer during the implementation stage.
SA_MASI: 2. Soundproof doors		

Item	Original text (as in ITB)	Amended specifications
Type / dimensions	As per final door schedule and drawings: • U-4 – full soundproof door, MDF, opening size 1000 × 2100 mm • U-5 – full soundproof door, MDF, opening size 1200 × 2100 mm • U-9 – full soundproof door, MDF, opening size 950 × 1500 mm Color(s) to be confirmed with designer during the implementation stage.	As per final door schedule and drawings: • U-4 – full soundproof door, HPL, opening size 1000 × 2100 mm • U-5 – full soundproof door, HPL, opening size 1200 × 2100 mm • U-9 – full soundproof door, HPL, opening size 950 × 1500 mm Color(s) to be confirmed with designer during the implementation stage.

- c) The deadline for submission of bids has been extended to 28 September 2026.
- d) All other terms and conditions of the solicitation documents, except as amended herein, shall remain unchanged and shall continue in full force and effect.